

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**  
**Annual Periodical Renewal Fire Certificate**

From:  
 Director  
 State Disaster Response & Fire Services  
 Andhra Pradesh, Vijayawada.

To:  
 The Commissioner,  
 APCRDA, Lenin Center, Governorpeta,  
 Vijayawada

**File No: 16664/GNT/MSB/2021, Date:22/03/2021**  
**Occupancy NoC RC Number: 5399/GNT/MSB/2018**

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Multi Storeyed Building of "VIVA" THE SCHOOL, a unit of Social Educational Trust, Sri Vasireddy Vidya Sagar,, represented by Sri Vasireddy Vidya Sagar, D.No.371, 372/1, 372/1A, 372/1C, 372/1D, 372/2A, 372/2B, 373/2, 373/3 & 375/B, Namburu Village, Pedakakani Mandal, Guntur District - Regarding.

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
  3. This Office NOC for Occupancy Rc No. 5399/GNT/MSB/2018, Dt.20/12/2018
  4. Renewal NOC For Occupancy 5399/GNT/MSB/2018, Dt.20/12/2019
  5. Online Application for Renewal NOC of Sri Vasireddy Vidya Sagar, D.No.371, 372/1, 372/1A, 372/1C, 372/1D, 372/2A, 372/2B, 373/2, 373/3 & 375/B, Namburu Village, Pedakakani Mandal, Guntur District - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 22-03-2021.

<< 0 >>


The Management of "VIVA" THE SCHOOL, a unit of Social Educational Trust, Sri Vasireddy Vidya Sagar,, represented by Sri Vasireddy Vidya Sagar, D.No.371, 372/1, 372/1A, 372/1C, 372/1D, 372/2A, 372/2B, 373/2, 373/3 & 375/B, Namburu Village, Pedakakani Mandal, Guntur District has requested to issue Annual Periodical Fire Certificate for period 2020-2021 duly remitting the Fire Precautionary fee for Rs.264656/- vide challan No. 41346797052020, Dated 27/01/2021 at SBI, Online Payment.


**"VIVA" THE SCHOOL, A unit of Social Educational Trust, Sri Vasireddy  
 Vidya Sagar**

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate Sri Vasireddy Vidya Sagar D.No.371, 372/1, 372/1A, 372/1C, 372/1D, 372/2A, 372/2B, 373/2, 373/3 & 375/B, Namburu Village, Pedakakani Mandal, Guntur District, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

202.83.28.165/noc/home.html#final\_noc\_r/100395

  
**Principal**  
**VIVA THE SCHOOL**  
 NAMBUR (V), Pedakakani (M), Guntur (Dt) - 522 508

  
**Secretary**  
**VIVA THE SCHOOL**  
 NAMBUR (V), Pedakakani (M), Guntur (Dt.) - 522 508

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 20/12/2020 to 19/12/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

1. This Renewal NOC is issued from the Fire Safety Point of view only basing on the recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
2. This Renewal NOC is valid for five years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection Certificate, duly remitting the user charges as per G.O.Ms.No.169, Home (Prisons & Fire Service) Department. Dt. 19-12-2019. Two months before expire of this No Objection Certificate.
3. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided by the building as per Occupancy NOC at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of an outbreak of Fire.
4. The Renewal NOC issued based on the Inspection Committee report.



16664/GNT/MSB/2021

Your Sincerely,

*[Signature]*  
20/12/2021

Director

State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

Copy to Sri Vasireddy Vidya Sagar, "VIVA" THE SCHOOL, a unit of Social Educational Trust, Sri Vasireddy Vidya Sagar, D.No.371, 372/1, 372/1A, 372/1C, 372/1D, 372/2A, 372/2B, 373/2, 373/3 & 375/B, Namburu Village, Pedakakani Mandal, Guntur District.

Copy to Chief Office for Record Purpose

Copy to Regional Fire Officer Concerned

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

202.83.28.165/noc/home.html#/final\_noc\_r/100395

*[Signature]*  
Principal

VIVA THE SCHOOL

NAMBUR (V), Pedakakani (M), Guntur (Dt) - 522 508

*[Signature]*  
Secretary

VIVA THE SCHOOL

NAMBUR (V), Pedakakani (M), Guntur (Dt) - 522 508